

Radiator Lockshield Valve Type M



Only allow work on heating water systems to be performed by qualified personnel and in accordance with the respective applicable regulations, guidelines and rules of engineering.




Refer in particular to:

DIN 18 380: Heating systems and central hot water supply systems

VDI 2035: Scale formation in domestic water heating systems and water heating systems

BGV: German Professional Association Regulations
(accident prevention regulations)





Shut off

- Remove blind cap **1**
- Turn spindle **2** to the right until reaching the stop using Allen key 4 mm (valve closed)

Presetting

- Remove blind cap **1**
- Turn off spindle **3** to the right until reaching the stop using Allen key 3 mm and perform the presetting by turning to the right according to the scheme.

Draining

- Shut off the valve (see above)
- Draining is performed by connecting a standard hose connection

The illustrations are symbolic and may differ from the respective product. Errors and technical changes reserved.

06/2017